

37633

Does the council have a specification for commercial buildings which create vehicle crossovers that bisect the pavement?

[Please see the attached document](#)

Are the commercial premises required to provide drop kerbs or suitable access for wheelchairs to be able to use the pavement?

If so, how is this enforced?

[Suitable access should be provided for wheelchairs; this is by the attached detail, or if the footway is replaced by carriageway over the access, then dropped kerbs should be provided at either side.](#)

[Enforcement would either be by the Road Construction Consent team if part of a Road Construction Consent application, or by the Permits Team if this relates to a permit.](#)