

57216

Information held regarding a sewage/drainage issue within the communal stairwell.

A new tenant has moved in and there seems to be a sewage/drainage issue within the communal stairwell from 2020-2022.

The Edinburgh Shared Repairs Service hold some information relating to the sole drainage defect reported in the communal stairwell during the period indicated. They have only attended the property to carry out jetting of the blocked drainage systems. No investigative works have been carried out.

The work was carried out by ScotDrain and the recorded details on 06/11/2020 are:

High Pressure Jet Unblock, Clean & Flush

Communal Internal Disconnecting Buchan Trap

Blocked trap was creating the foul smell