

Environmental & Consumer Services Department

Noise measurement Report

LOCATION:

COMPLAINT DETAILS:

30-32 Clerk St

92376 92377

METER TYPE:

Btk 2250

METER SERIAL NUMBER:

4231 2463832

MEASURING POSITION:

Backdoor, window approx 4m high 1.8m from window

WEATHER CONDITIONS:

TS 13°C, overcast
roads wet, wind 7 mph
from WSW, light rain

(First floor)
① Extract on
max +
supply max

Second floor
② Extract on
max + supply
max

FREQUENCY (Hz)	(1)	(2)	(3)	(4)	(5)	(6)	NR 20	NR 25	NR 30
31.5	33.6	35.5					69	72	76
63	39.0	38.5					51	55	59
125	35.5	38.6					39	44	48
250	30.3	31.6					31	35	40
500	25.3	27.6					24	29	34
1000	21.9	25.3					20	25	30
2000	16.0	18.9					17	22	27
4000	12.3	13.7					14	20	25
8000	12.3	12.5					13	18	23
A	27.8	30.3							
LIN	49.0	55.3							

DETAILS:

Cable deck start = 93.9 dB
" " end = 93.9 dB

Sanded ladder on 2nd floor
20 measured there.

OFFICERS PRESENT: