

## 62311 Noise Assessment Heritage Grange development

Whether any post construction or post occupation noise monitoring has been carried out, and if not, confirmation that this information is not held.

Which Council department and or officer reviewed and accepted the noise assessment, including any conditions attached to planning approval.

Whether the Council holds any updated or supplementary noise assessments for the development.

Whether the Council has considered the use of noise monitoring or enforcement technologies including noise cameras, and whether any discussions have taken place with Transport Scotland or Police Scotland in this regard.

The information you have requested is available on the Council's [Planning Portal](#) under reference number 14/04860/FUL.

What environmental noise thresholds are applied by the Council for residential areas, including internal standards for bedrooms and living areas, and external standards for gardens and public spaces.

In 2014, the recommendation from Environmental Protection was that internal standards should meet:

Bedrooms - 30 dB LAeq, 23:00 – 07:00 and 45 dB L<sub>Amax</sub>

Living Rooms - 35 dB LAeq, 07:00 – 23:00.

There was no external standard applied.

What standards, guidance or health-based criteria are relied upon in determining whether an environment is considered acceptable.

The above standards are from BS 8233:2014: Guidance on sound insulation and noise reduction for buildings - Code of Practice.