

63078 RAAC Surveys

Please confirm if you carried out any form of:

- a) annual inspections

Yes.

- b) regular surveys on school buildings where Reinforced Autoclaved Aerated Concrete was found.

Yes.

Where you have confirmed RAAC present in any of your buildings that have been marked by surveyors as at red or amber risk, please outline the work that has been carried out.

Please refer to the following list:

Cramond Primary School – RAAC roofs replaced

Trinity Primary School – RAAC roofs replaced

Pentland Primary School – RAAC roofs replaced

Colinton Primary School - RAAC roofs replaced

Currie High School – replaced by new school – old (RAAC) building now demolished

Trinity Academy – Building (with RAAC) now demolished

Fox Covert Primary School – structural steel installed in dining and gym halls. Propping in place in other locations; on-going monitoring regime in place; Design of new school underway

Lorne Primary School – structural steel installed in RAAC areas; RAAC in good condition; on-going monitoring regime in place

Darroch Annexe Former Tech Block – RAAC in good condition; area of building containing RAAC not in use; subject to on-going monitoring

Blackhall Library – Property fully closed. Propping has been installed. On-going consultation on longer term future; on-going monitoring regime in place

Peffer Place Depot – RAAC in good condition: areas isolated; building is marked for disposal; on-going monitoring regime in place

If you have carried out work as indicated in question 1, please

- a) provide a copy of any costings

Please refer to the attached documents which provide the Capital and Revenue spend on RAAC projects.

- b) confirm if funds to carry out work were found from within existing budgets or if extra funding was provided by the Scottish Government.

Funding to date has been met via a Capital Budget allocation and the wider Revenue Budget in the financial years concerned.

If you have not carried out work as indication, please confirm the reasons as to why this work has not yet been carried out.

Not applicable. Please refer to A2 above.