



Certificate Reference: Copy of Uy14

A. DETAILS OF THE CLIENT

1.1 Client name and address:  
Rockwell Property Group Ltd  
58long Lane  
Dundee  
DD51HH

B. INSTALLATION ADDRESS

1.2 Installation address:  
107 Caroline Terrace  
Edinburgh

EH128QU

C. DESCRIPTION AND EXTENT OF THE INSTALLATION

2.1 Description of installation: Domestic

2.2 Extent of the installation covered by this Certificate:  
N/A

2.3 Installation is: N/A

2.4 LABC No.: N/A

D. FOR DESIGN

I/We, being the person(s) responsible for the design of the electrical installation (as indicated by my/our signatures below), particulars of which are described above, having exercised reasonable skill and care when carrying out the design, hereby CERTIFY that the design work for which I/we have been responsible is to the best of my/our knowledge and belief in accordance with BS 7671: 2018, amended to Mar 2022 (date) except for the departures, if any, detailed as follows:

3.1 Details of departures from BS 7671 (Regulations 120.3, 133.1.3 and 133.5):  
N/A

3.2 Details of permitted exceptions (Regulation 411.3.3). Where applicable, a suitable risk assessment(s) must be attached to this Certificate:  
N/A

Risk assessment attached: N/A

3.3 The extent of liability of the signatory or signatories is limited to the work described above as the subject of this Certificate.  
For the DESIGN of the installation: \*\*(Where there is mutual responsibility for the design)

Signature:

N/A

Name: [Redacted]

Designer No.1

Date: 21/07/2025

Signature:

N/A

Name: N/A

Designer No.2\*\*

Date: N/A

Certificate Reference: Copy of Uy14

## E. FOR CONSTRUCTION

I, being the person responsible for the construction of the electrical installation (as indicated by my signature below), particulars of which are described above, having exercised reasonable skill and care when carrying out the construction, hereby CERTIFY that the construction work for which I have been responsible is to the best of my knowledge and belief in accordance with BS 7671:2018, amended to Mar 2022 (date) except for the departures, if any, detailed as follows:

### 4.1 Details of departures from BS 7671 (Regulations 120.3 and 133.5):

N/A

### 4.2 The extent of liability of the signatory or signatories is limited to the work described above as the subject of this Certificate.

For CONSTRUCTION of the installation:

Signature:

N/A

Name:

[Redacted]

Constructor

Date: 21/07/2025

## F. FOR INSPECTION AND TESTING

I, being the person responsible for the inspection and testing of the electrical installation (as indicated by my signature below), particulars of which are described above, having exercised reasonable skill and care when carrying out the inspection and testing, hereby CERTIFY that the work for which I have been responsible is to the best of my knowledge and belief in accordance with BS 7671:2018, amended to Mar 2022 (date) except for the departures, if any, detailed as follows:

### 5.1 Details of departures from BS 7671 (Regulations 120.3 and 133.5):

N/A

### 5.2 The extent of liability of the signatory or signatories is limited to the work described above as the subject of this Certificate.

For INSPECTING AND TESTING of the installation:

Signature:

N/A

Name:

[Redacted]

Inspector

Date: 21/07/2025

## G. NEXT INSPECTION

### 6.1 I/We, the designer(s), recommend that this installation is further inspected and tested after an interval of not more than:

4 Years

Certificate Reference: Copy of Uy14

H. PARTICULARS OF THE SIGNATORIES TO THE ELECTRICAL INSTALLATION CERTIFICATE

|                                                                                                                                                                                                                                                                      |                                                                                                                                                                                                                                        |                                                                                                                                                                                                                                                                  |                                                                                                                                                                                                                                                                |
|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>7.1 DESIGNER (No.1)</b><br><b>Company:</b><br>DS Electric<br><br><b>Address:</b><br>Northbridge<br>Bathgate<br>EH484PN<br><br><b>Telephone:</b> N/A<br><br><b>Cps scheme:*</b> ECA<br><br><b>Registration number:</b> APL48260-1<br><br><b>Branch number:</b> N/A | <b>7.2 DESIGNER (No.2) (if applicable)</b><br><b>Company:</b><br>N/A<br><br><b>Address:</b><br>N/A<br><br><b>Telephone:</b> N/A<br><br><b>Cps scheme:*</b> N/A<br><br><b>Registration number:</b> N/A<br><br><b>Branch number:</b> N/A | <b>7.3 CONSTRUCTOR</b><br><b>Company:</b><br>DS Electric<br><br><b>Address:</b><br>Northbridge<br>Bathgate<br>EH484PN<br><br><b>Telephone:</b> N/A<br><br><b>Cps scheme:*</b> ECA<br><br><b>Registration number:</b> APL48260-1<br><br><b>Branch number:</b> N/A | <b>7.4 INSPECTOR</b><br><b>Company:</b><br>DS Electric<br><br><b>Address:</b><br>Northbridge<br>Bathgate<br>EH484PN<br><br><b>Telephone:</b> N/A<br><br><b>Cps scheme:*</b> ECA<br><br><b>Registration number:</b> APL48260-1<br><br><b>Branch number:</b> N/A |
|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|

*\*Or other relevant organisation*

I. SUPPLY CHARACTERISTICS AND EARTHING ARRANGEMENTS

|                                                 |                                                                                                                                                                                                                                                                                           |                                                                                                                                                                                                                                                                   |                                                                                                                                                        |
|-------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>8.1 Earthing arrangements:</b><br><br>TN-C-S | <b>8.3 Nature of supply parameters</b><br><b>Nominal voltage U<sub>o</sub>, (L-L):</b> N/A V <sup>(1)</sup><br><b>Nominal frequency, f:</b> 50 Hz <sup>(1)</sup><br><b>External earth fault loop imp. Z<sub>e</sub>:</b> 0.11 Ω <sup>(2)</sup><br><b>Confirmation of supply polarity:</b> | <b>Nominal voltage U<sub>o</sub>, (L-E):</b> 230 V <sup>(1)</sup><br><b>Prospective fault current, I<sub>pf</sub>:</b> 2.2 kA <sup>(2)</sup><br><b>Number of supplies:</b> 1<br><b>Confirmation of phase rotation:</b> N/A<br><b>Other sources of supply:</b> N/A | <b>8.4 Supply protective device</b><br><b>BS (EN):</b> LIM<br><b>Type:</b> LIM<br><b>Rated current:</b> LIM A<br><b>Short-circuit capacity:</b> LIM kA |
|-------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------|

*Note: (1) by enquiry, (2) by enquiry or by measurement*

J. PARTICULARS OF INSTALLATION REFERRED TO IN THE CERTIFICATE

|                                                                 |                                                                                                                     |                                                                                                                                                                                                                                        |
|-----------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>9.1 Means of earthing</b><br><br>Distributor's facility:<br> | <b>9.2</b><br><b>Maximum demand (load):</b> 100 Amps<br><br><b>Method of protection against electric shock:</b> ADS | <b>9.3 Details of installation earth electrode (where applicable)</b><br><b>Type: (e.g. rod(s), tape etc.)</b> N/A<br><b>Location:</b> N/A<br><br><b>Method of measurement:</b> N/A<br><br><b>Electrode resistance to earth:</b> N/A Ω |
|-----------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|

Certificate Reference: Copy of Uy14

K. MAIN PROTECTIVE EARTHING AND BONDING CONDUCTORS

|                                               |           |        |      |      |                 |                                   |   |                   |           |
|-----------------------------------------------|-----------|--------|------|------|-----------------|-----------------------------------|---|-------------------|-----------|
| 10.1 Earthing conductor:                      | Material: | Copper | csa: | 16   | mm <sup>2</sup> | Connection / continuity verified: | ✓ | 0.04              | Ω         |
| 10.2 Main protective bonding conductors:      | Material: | Copper | csa: | 10   | mm <sup>2</sup> | Connection / continuity verified: | ✓ |                   |           |
| 10.3 Main protective bonding conductor(s) to: |           |        |      |      |                 |                                   |   |                   |           |
| Water:                                        | ✓         | 0.02   | Ω    | Gas: | ✓               | 0.03                              | Ω | Structural steel: | N/A N/A Ω |
| Lightning protection:                         | N/A       | N/A    | Ω    | Oil: | N/A             | N/A                               | Ω | Other (specify):  | N/A N/A Ω |

L. MAIN SWITCH/SWITCH-FUSE/CIRCUIT-BREAKER/RCD

|                             |                    |  |                              |     |                                  |                        |     |                                                      |           |     |
|-----------------------------|--------------------|--|------------------------------|-----|----------------------------------|------------------------|-----|------------------------------------------------------|-----------|-----|
| 11.1                        |                    |  |                              |     | Fuse / device rating or setting: | 100                    | A   | 11.2 If RCD main switch                              |           |     |
| Location:                   | meter housing      |  |                              |     | Current rating:                  | 100                    | A   | Rated residual (I <sub>Δn</sub> ) operating current: | N/A       | mA  |
| BS (EN):                    | 60947-2 MCCB       |  | No. of poles:                | 2   |                                  |                        |     | Rated time delay:                                    | N/A       | ms  |
| Supply conductors material: | Copper             |  | Voltage rating:              | 230 | V                                |                        |     | Measured operating time:                             | N/A       | ms  |
| Supply conductors csa:      | 25 mm <sup>2</sup> |  | kA capacity: (if applicable) | Na  | kA                               | Current rating:        | N/A | A                                                    | RCD Type: | N/A |
|                             |                    |  |                              |     |                                  | Test button operation: | N/A |                                                      |           |     |

M. COMMENTS ON EXISTING INSTALLATION

In the case of an alteration or addition see Regulation 644.1.2

N/A

N. SCHEDULES

ⓘ This certificate is valid only when 1 Schedule(s) of Circuit Details & Test Results and 1 Schedule(s) of Inspections are attached.

Certificate Reference: **Copy of Uy14**

## O. SCHEDULE OF INSPECTIONS

All items inspected in order to confirm, as appropriate, compliance with the relevant clauses in BS 7671:

|                      |      |                |     |
|----------------------|------|----------------|-----|
| Acceptable Condition | PASS | Not Applicable | N/A |
|----------------------|------|----------------|-----|

| Item No. | Description                                                       | Outcome |
|----------|-------------------------------------------------------------------|---------|
| 1.0      | Condition of consumer's intake equipment (Visual inspection only) | NA      |
| 2.0      | Parallel or switched alternative sources of supply                | NA      |
| 3.0      | Protective measure: Automatic Disconnection of Supply (ADS)       | NA      |
| 4.0      | Basic protection                                                  | NA      |
| 5.0      | Protective measures other than ADS                                | NA      |
| 6.0      | Additional protection                                             | NA      |
| 7.0      | Distribution equipment                                            | NA      |
| 8.0      | Circuits (Distribution and Final)                                 | NA      |
| 9.0      | Isolation and switching                                           | NA      |
| 10.0     | Current-using equipment (permanently connected)                   | NA      |
| 11.0     | Identification and notices                                        | NA      |
| 12.0     | Location(s) containing a bath or shower                           | NA      |
| 13.0     | Other special installations or locations                          | NA      |
| 14.0     | Prosumer's low voltage electrical installation(s)                 | NA      |



Certificate Reference: Copy of Uy14

P. GUIDANCE FOR RECIPIENT

This safety Certificate has been issued to confirm that the electrical installation work to which it relates has been designed, constructed, inspected and tested in accordance with BS 7671.

You should have received an 'original' Certificate and the person that issued the Certificate should have retained a duplicate. If you were the person ordering the work, but not the owner of the installation, you should pass this Certificate, or a full copy of it including the schedules, immediately to the owner.

The 'original' Certificate should be retained in a safe place and be shown to any person inspecting or undertaking further work on the electrical installation in the future. If you later vacate the property, this Certificate will demonstrate to the new owner that the electrical installation complied with the requirements of BS 7671 at the time the Certificate was issued. The Construction (Design and Management) Regulations require that, for a project covered by those Regulations, a copy of this Certificate, together with schedules, is included in the project health and safety documentation.

For safety reasons, the electrical installation will need to be inspected at appropriate intervals by a skilled person or persons, competent in such work. The maximum time interval recommended before the next inspection is stated under 'RECOMMENDED DATE OF NEXT INSPECTION' below.

This Certificate is intended to be issued only for a new electrical installation or for new work associated with an addition or alteration to an existing installation. It should not have been issued for the inspection and testing of an existing electrical installation. An 'Electrical Installation Condition Report' should be issued for such an inspection.

This Certificate is only valid if the Schedule of Inspections has been completed to confirm that all relevant inspections have been carried out and where accompanied by Schedule(s) of Circuit Details and Test Results.

Where the installation includes a residual current device (RCD) it should be tested six-monthly by pressing the button marked 'T' or 'Test'. The device should switch off the supply and should then be switched on to restore the supply. If the device does not switch off the supply when the button is pressed, seek expert advice. **For safety reasons it is important that this instruction is followed.**

Where the installation includes an arc fault detection device (AFDD) having a manual test facility it should be tested six-monthly by pressing the test button. Where an AFDD has both a test button and automatic test function, manufacturer's instructions shall be followed with respect to test button operation.

Where the installation includes a surge protective device (SPD) the status indicator should be checked to confirm it is in operational condition in accordance with manufacturer's information. If the indication shows that the device is not operational, seek expert advice. **For safety reasons it is important that this instruction is followed.**

Where the installation includes alternative or additional sources of supply, warning notices should be found at the origin or meter position or, if remote from the origin, at the consumer unit or distribution board and at all points of isolation of all sources of supply.

IMPORTANT

This installation should be periodically inspected and tested and a report on its condition obtained, as prescribed in BS 7671 requirements for electrical installations

|                                      |              |
|--------------------------------------|--------------|
| Date installation works completed:   | 21/07/2025   |
| Recommended date of next inspection: | 21/07/2029   |
| Certificate reference / number:      | Copy of Uy14 |

